



<b>Engineering Judgement Record</b>	
<b>Applicant's Name:</b> <u>EZ Taping Systems</u>	<b>Project Number:</b> <u>3024920</u>
<b>Product:</b> <u>Approval Tested Wall Assembly to CAN/ULC S101, NFPA 251, and UL 263</u>	
<b>Cat. No. :</b> _____	
<b>Applicable Standards:</b> <u>UBC Standard 7-1-1994, ASTM E119, CAN/ULC S-101, NFPA 251, and UL 263</u>	
<b>Rating:</b> <u>60 Minute Fire Wall Assemblies</u>	<b>Section or Clause:</b> _____
<b>Description of the Feature in question:</b>	
<ul style="list-style-type: none"> <li>• Add Standard approvals to EZ Taping's Fire Tape® listings EZT/WA 60-01 and EZT/WA 60-02.</li> </ul>	
<b>Rationale for the Engineering Judgement:</b>	
<ul style="list-style-type: none"> <li>• UBC Standard 7-1-1994, ASTM E119, CAN/ULC S-101, NFPA 251, and UL 263 are similar. Any differences between these standards will not change the results stated in Test Report #13164-764-2 and #13164-764-3 (referencing UBC Standard 7-1-1994 and ASTM E119). Thus EZ Taping's Fire Tape® is eligible for listing under CAN/ULC S-101, NFPA 251, and UL 263 for both EZT/WA 60-01 and EZT/WA 60-02.</li> </ul>	
<b>Engineer:</b>	 James F. Turgeson
<b>Reviewer:</b>	 Nigel Stamp

Engineering Judgement (3024920) EZ Tape 03 May 2002



05/03/02



Intertek Testing Services NA, Inc.

8431 Murphy Drive, Middleton, WI 53562

Telephone 608-836-4400 Fax 608-831-9279 Home Page www.etlsemko.com

