

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM
LISTING SERVICE

LISTING No. 4485-1332:100

CATEGORY: Opening Protection (Firestopping)

LISTEE: Specified Technologies, 200 Evans Way #2, Somerville NJ 08876
Contact: *James Stahl Jr. (908) 526-8000 FAX (908) 231-8415

DESIGN: **SPECSEAL** systems (sealant, putty, putty pads, wrap strip, mortar and collar). Refer to listee's data sheet for detailed product description and operational considerations. Additional information may be found in the UL Fire Resistance Directory.

INSTALLATION: In accordance with **listee's** printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: **Listee's** name, product designation and UL label.

APPROVAL: Listed as %hour, 3-hour and 4-hour fire-rated firestopping systems.
Approved 4 hour Systems: W-L-1171, -2194, -2195 and W-J-1070, -2059 and -2060. Refer to UL Fire Resistance Directory for detailed information for the specific assembly.

*Rev. 07-29-2003



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 6, 2007**

Listing Expires June 30, 2008

Authorized By: **MIKE TANAKA**, Senior Deputy State Fire Marshal
Program Manager